

January 26, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Rolla High School

WorkOrder: 24010250

Dear John Cable:

TEKLAB, INC received 60 samples on 1/3/2024 12:57:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Elizabeth A. Hurley
Director of Customer Service
(618)344-1004 ex 33
ehurley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	13
Chain of Custody	Appended

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425

Phone (618) 344-1004

Fax (618) 344-1005

Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425

Phone (618) 344-1004

Fax (618) 344-1005

Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415

Phone (217) 698-1004

Fax (217) 698-1005

Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515

Phone (630) 324-6855

Fax

Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214

Phone (913) 541-1998

Fax (913) 541-1998

Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010250-001A	31-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 8:24	12/30/2023 10:00
24010250-002A	31-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 8:29	12/30/2023 10:00
24010250-003A	32-A	NELAP		0.0010	0.0030	mg/L	1	01/18/2024 8:33	12/30/2023 10:00
24010250-004A	32-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:03	12/30/2023 10:00
24010250-005A	33-A	NELAP		0.0010	0.0018	mg/L	1	01/18/2024 9:08	12/30/2023 10:00
24010250-006A	33-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:12	12/30/2023 10:00
24010250-007A	34-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:33	12/30/2023 10:00
24010250-008A	34-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:16	12/30/2023 10:00
24010250-009A	35-A	NELAP		0.0010	0.0010	mg/L	1	01/18/2024 9:21	12/30/2023 10:00
24010250-010A	35-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:25	12/30/2023 10:00
24010250-011A	36-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:29	12/30/2023 10:00
24010250-012A	36-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 9:59	12/30/2023 10:00
24010250-013A	37-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 10:04	12/30/2023 10:00
24010250-014A	37-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 10:08	12/30/2023 10:00
24010250-015A	38-A	NELAP		0.0010	0.0029	mg/L	1	01/18/2024 10:12	12/30/2023 10:00
24010250-016A	38-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 10:17	12/30/2023 10:00
24010250-017A	39-A	NELAP		0.0010	0.0017	mg/L	1	01/18/2024 10:29	12/30/2023 10:00
24010250-018A	39-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 10:21	12/30/2023 10:00
24010250-019A	40-A	NELAP		0.0010	0.0020	mg/L	1	01/18/2024 10:25	12/30/2023 10:00
24010250-020A	40-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 10:55	12/30/2023 10:00
24010250-021A	41-A	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 11:00	12/30/2023 10:00
24010250-022A	41-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 11:04	12/30/2023 10:00
24010250-023A	42-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 11:08	12/30/2023 10:00
24010250-024A	42-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 11:13	12/30/2023 10:00
24010250-025A	43-A	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 11:17	12/30/2023 10:00
24010250-026A	43-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 11:21	12/30/2023 10:00
24010250-027A	44-A	NELAP		0.0010	0.0016	mg/L	1	01/18/2024 11:25	12/30/2023 10:00
24010250-028A	44-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:05	12/30/2023 10:00
24010250-029A	45-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:09	12/30/2023 10:00
24010250-030A	45-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:13	12/30/2023 10:00
24010250-031A	46-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:18	12/30/2023 10:00
24010250-032A	46-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:22	12/30/2023 10:00
24010250-033A	47-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:26	12/30/2023 10:00
24010250-034A	47-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:30	12/30/2023 10:00
24010250-035A	48-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 13:05	12/30/2023 10:00
24010250-036A	48-B	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 13:09	12/30/2023 10:00
24010250-037A	49-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 12:35	12/30/2023 10:00
24010250-038A	49-B	NELAP		0.0010	0.0014	mg/L	5	01/26/2024 2:50	12/30/2023 10:00
24010250-039A	50-A	NELAP		0.0010	0.0039	mg/L	1	01/18/2024 13:14	12/30/2023 10:00
24010250-040A	50-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 13:18	12/30/2023 10:00
24010250-041A	51-A	NELAP		0.0010	0.0097	mg/L	1	01/18/2024 13:22	12/30/2023 10:00
24010250-042A	51-B	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 13:26	12/30/2023 10:00
24010250-043A	52-A	NELAP		0.0010	0.0231	mg/L	1	01/18/2024 13:31	12/30/2023 10:00
24010250-044A	52-B	NELAP		0.0010	0.0030	mg/L	5	01/26/2024 2:54	12/30/2023 10:00
24010250-045A	53-A	NELAP		0.0010	0.0166	mg/L	1	01/18/2024 13:35	12/30/2023 10:00
24010250-046A	53-B	NELAP		0.0010	0.0017	mg/L	5	01/26/2024 2:58	12/30/2023 10:00
24010250-047A	54-A	NELAP		0.0010	0.0251	mg/L	1	01/18/2024 14:01	12/30/2023 10:00
24010250-048A	54-B	NELAP		0.0010	0.0028	mg/L	5	01/26/2024 4:00	12/30/2023 10:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010250-049A	55-A	NELAP		0.0010	0.0163	mg/L	1	01/18/2024 14:05	12/30/2023 10:00
24010250-050A	55-B	NELAP		0.0010	0.0073	mg/L	5	01/26/2024 3:02	12/30/2023 10:00
24010250-051A	56-A	NELAP		0.0010	0.0104	mg/L	1	01/18/2024 14:18	12/30/2023 10:00
24010250-052A	56-B	NELAP		0.0010	0.0038	mg/L	1	01/18/2024 14:22	12/30/2023 10:00
24010250-053A	57-A	NELAP		0.0010	0.0457	mg/L	5	01/26/2024 3:31	12/30/2023 10:00
24010250-054A	57-B	NELAP		0.0010	0.0167	mg/L	1	01/18/2024 14:27	12/30/2023 10:00
24010250-055A	58-A	NELAP		0.0010	0.0148	mg/L	1	01/18/2024 14:31	12/30/2023 10:00
24010250-056A	58-B	NELAP		0.0010	0.0020	mg/L	1	01/18/2024 14:57	12/30/2023 10:00
24010250-057A	59-A	NELAP		0.0010	0.0183	mg/L	1	01/18/2024 15:01	12/30/2023 10:00
24010250-058A	59-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 15:06	12/30/2023 10:00
24010250-059A	60-A	NELAP		0.0010	0.0160	mg/L	1	01/18/2024 15:10	12/30/2023 10:00
24010250-060A	60-B	NELAP		0.0010	0.0024	mg/L	1	01/18/2024 15:14	12/30/2023 10:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216940 **SampType: MBLK** Units mg/L

SampID: MBLK-216940

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024

Batch 216940 **SampType: LCS** Units mg/L

SampID: LCS-216940

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0470	0.0500	0	93.9	85	115	01/17/2024

Batch 216940 **SampType: MS** Units mg/L

SampID: 24010249-057AMS

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.130	0.1000	0.004716	124.9	70	130	01/17/2024

Batch 216940 **SampType: MSD** Units mg/L

SampID: 24010249-057AMSD

RPD Limit: 20

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.115	0.1000	0.004716	110.1	0.1296	12.04	01/17/2024

Batch 216940 **SampType: MS** Units mg/L

SampID: 24010250-007AMS

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.118	0.1000	0.0009536	116.6	70	130	01/18/2024

Batch 216940 **SampType: MSD** Units mg/L

SampID: 24010250-007AMSD

RPD Limit: 20

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.100	0.1000	0.0009536	99.3	0.1176	15.90	01/18/2024

Batch 216941 **SampType: MBLK** Units mg/L

SampID: MBLK-216941

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024

Batch 216941 **SampType: LCS** Units mg/L

SampID: LCS-216941

Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0470	0.0500	0	93.9	85	115	01/17/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216941		SampType: MS		Units mg/L							
SampID: 24010250-055AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.124	0.1000	0.01481	109.4	70	130	01/18/2024	

Batch 216941		SampType: MSD		Units mg/L							
SampID: 24010250-055AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.121	0.1000	0.01481	106.0	0.1242	2.75	01/18/2024	

Batch 216942		SampType: MBLK		Units mg/L							
SampID: MBLK-216942											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 216942		SampType: LCS		Units mg/L							
SampID: LCS-216942											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0470	0.0500	0	93.9	85	115	01/17/2024	

Batch 216942		SampType: MS		Units mg/L							
SampID: 24010250-017AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.109	0.1000	0.001684	106.9	70	130	01/18/2024	

Batch 216942		SampType: MSD		Units mg/L							
SampID: 24010250-017AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.109	0.1000	0.001684	107.2	0.1086	0.28	01/18/2024	

Batch 216942		SampType: MS		Units mg/L							
SampID: 24010250-027AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0862	0.1000	0.001551	84.6	70	130	01/18/2024	

Batch 216942		SampType: MSD		Units mg/L							
SampID: 24010250-027AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0967	0.1000	0.001551	95.1	0.08617	11.51	01/18/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216946		SampType: MBLK		Units mg/L							
SampID: MBLK-216946											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 216946		SampType: LCS		Units mg/L							
SampID: LCS-216946											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0470	0.0500	0	93.9	85	115	01/17/2024	

Batch 216946		SampType: MS		Units mg/L							
SampID: 24010250-037AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.108	0.1000	0.0003753	107.9	70	130	01/18/2024	

Batch 216946		SampType: MSD		Units mg/L							
SampID: 24010250-037AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0956	0.1000	0.0003753	95.3	0.1083	12.42	01/18/2024	

Batch 216946		SampType: MS		Units mg/L							
SampID: 24010250-045AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.125	0.1000	0.01661	108.2	70	130	01/18/2024	

Batch 216946		SampType: MSD		Units mg/L							
SampID: 24010250-045AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.117	0.1000	0.01661	100.8	0.1248	6.15	01/18/2024	

Batch 217640		SampType: MBLK		Units mg/L							
SampID: MBLK-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/26/2024	

Batch 217640		SampType: LCS		Units mg/L							
SampID: LCS-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.476	0.5000	0	95.2	85	115	01/26/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217640		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010250-048AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.459	0.5000	0.002802	91.3	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010250-048AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010		0.468	0.5000	0.002802	93.0	0.4595	1.81	01/26/2024		

Batch 217640		SampType: MS		Units mg/L							Date Analyzed
SampID: 24010251-032AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.891	1.000	0.002569	88.9	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							RPD Limit: 20	Date Analyzed
SampID: 24010251-032AMSD												
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed		
Lead		0.0010	E	0.931	1.000	0.002569	92.9	0.8914	4.38	01/26/2024		



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010250

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Carrier: John Cable

Received By: LEH

Completed by:

Amber Dilallo

Reviewed by:

Ellie Hopkins

On:

03-Jan-24

Amber Dilallo

On:

03-Jan-24

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- | | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C N/A |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

14010249

001	1-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	1-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	2-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	2-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	3-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	3-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	4-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	4-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	5-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	5-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	6-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	6-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	7-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	7-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	8-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	8-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	9-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	9-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	10-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	10-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	11-A	DRINKING WATER	LEAD	12/30/23 @ 1000
021	11-B	DRINKING WATER	LEAD	12/30/23 @ 1000
022	12-A	DRINKING WATER	LEAD	12/30/23 @ 1000
023	12-B	DRINKING WATER	LEAD	12/30/23 @ 1000
024	12-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	13-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	13-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	14-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	14-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	15-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	15-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	16-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	16-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	17-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	17-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	18-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	18-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	19-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	19-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	20-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	20-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	21-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	21-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	22-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	22-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	23-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	23-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	24-A	DRINKING WATER	LEAD	12/30/23 @ 1000

24010249

048	24-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	25-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	25-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	26-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	26-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	27-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	27-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	28-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	28-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	29-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	29-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	30-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	30-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061 4010 ²⁵⁰	31-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	31-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	32-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	32-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	33-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	33-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	34-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	34-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	35-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	35-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	36-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	36-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	37-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	37-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	38-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	38-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	39-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	39-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	40-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	40-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	41-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	41-B	DRINKING WATER	LEAD	12/30/23 @ 1000
083	42-A	DRINKING WATER	LEAD	12/30/23 @ 1000
084	42-B	DRINKING WATER	LEAD	12/30/23 @ 1000
085	43-A	DRINKING WATER	LEAD	12/30/23 @ 1000
086	43-B	DRINKING WATER	LEAD	12/30/23 @ 1000
087	44-A	DRINKING WATER	LEAD	12/30/23 @ 1000
088	44-B	DRINKING WATER	LEAD	12/30/23 @ 1000
089	45-A	DRINKING WATER	LEAD	12/30/23 @ 1000
090	45-B	DRINKING WATER	LEAD	12/30/23 @ 1000
091	46-A	DRINKING WATER	LEAD	12/30/23 @ 1000
092	46-B	DRINKING WATER	LEAD	12/30/23 @ 1000
093	47-A	DRINKING WATER	LEAD	12/30/23 @ 1000
094	47-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010250

035	48-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	48-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	49-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	49-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	50-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	50-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	51-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	51-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	52-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	52-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	53-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	53-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	54-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	54-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	55-A	DRINKING WATER	LEAD	12/30/23 @ 1000
051	56-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	56-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	57-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	57-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	58-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	58-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	59-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	59-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	60-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	60-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	61-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	61-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	62-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	62-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	63-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	63-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	64-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	64-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	65-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	65-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	66-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	66-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	67-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	67-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	68-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	68-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	69-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	69-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	70-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	70-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	71-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	71-B	DRINKING WATER	LEAD	12/30/23 @ 1000

241010251

023 72-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024 72-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025 73-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026 73-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027 74-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028 74-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029 75-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030 75-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031 76-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032 76-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033 77-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034 77-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035 78-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036 78-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037 79-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038 79-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039 80-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040 80-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041 81-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042 81-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043 82-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044 82-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045 83-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046 83-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047 84-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048 84-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049 85-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050 85-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051 86-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052 86-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053 87-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054 87-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055 88-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056 88-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057 89-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058 89-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059 90-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060 90-B	DRINKING WATER	LEAD	12/30/23 @ 1000

241010252

001 91-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002 91-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003 92-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004 92-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005 93-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006 93-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007 94-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008 94-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009 95-A	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

010	95-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	96-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	96-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	97-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	97-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	98-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	98-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	99-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	99-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	100-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	100-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	101-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	101-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	102-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	102-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	103-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	103-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	104-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	104-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	105-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	105-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	106-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	106-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	107-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	107-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	108-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	108-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	109-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	109-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	110-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	110-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	111-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	111-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	112-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	112-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	113-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	113-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	114-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	114-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	115-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	115-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	116-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	116-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	117-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	117-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	118-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	118-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

057	119-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	119-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	120-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	120-B	DRINKING WATER	LEAD	12/30/23 @ 1000
24010253	121-A	DRINKING WATER	LEAD	12/30/23 @ 1000
001	121-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	122-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	122-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	123-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	123-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	124-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	124-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	125-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	125-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	126-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	126-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	127-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	127-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	128-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	128-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	129-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	129-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	130-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	130-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	131-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	131-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	132-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	132-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	133-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	133-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	134-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	134-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	135-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	135-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	136-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	136-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	137-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	137-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	138-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	138-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	139-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	139-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	140-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	140-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	141-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	141-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	142-A	DRINKING WATER	LEAD	12/30/23 @ 1000

24010253

044	142-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	143-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	143-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	144-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	144-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	145-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	145-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	146-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	146-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	147-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	147-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	148-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	148-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	149-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	149-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	150-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	150-B	DRINKING WATER	LEAD	12/30/23 @ 1000
<u>4010254</u>	151-A	DRINKING WATER	LEAD	12/30/23 @ 1000
001	151-B	DRINKING WATER	LEAD	12/30/23 @ 1000
002	152-A	DRINKING WATER	LEAD	12/30/23 @ 1000
003	152-B	DRINKING WATER	LEAD	12/30/23 @ 1000
004	153-A	DRINKING WATER	LEAD	12/30/23 @ 1000
005	153-B	DRINKING WATER	LEAD	12/30/23 @ 1000
006	154-A	DRINKING WATER	LEAD	12/30/23 @ 1000
007	154-B	DRINKING WATER	LEAD	12/30/23 @ 1000
008	155-A	DRINKING WATER	LEAD	12/30/23 @ 1000
009	155-B	DRINKING WATER	LEAD	12/30/23 @ 1000
010	156-A	DRINKING WATER	LEAD	12/30/23 @ 1000
011	156-B	DRINKING WATER	LEAD	12/30/23 @ 1000
012	157-A	DRINKING WATER	LEAD	12/30/23 @ 1000
013	157-B	DRINKING WATER	LEAD	12/30/23 @ 1000
014	158-A	DRINKING WATER	LEAD	12/30/23 @ 1000
015	158-B	DRINKING WATER	LEAD	12/30/23 @ 1000
016	159-A	DRINKING WATER	LEAD	12/30/23 @ 1000
017	159-B	DRINKING WATER	LEAD	12/30/23 @ 1000
018	160-A	DRINKING WATER	LEAD	12/30/23 @ 1000
019	160-B	DRINKING WATER	LEAD	12/30/23 @ 1000
020	161-A	DRINKING WATER	LEAD	12/30/23 @ 1000
021	161-B	DRINKING WATER	LEAD	12/30/23 @ 1000
022	162-A	DRINKING WATER	LEAD	12/30/23 @ 1000
023	162-B	DRINKING WATER	LEAD	12/30/23 @ 1000
024	163-A	DRINKING WATER	LEAD	12/30/23 @ 1000
025	163-B	DRINKING WATER	LEAD	12/30/23 @ 1000
026	164-A	DRINKING WATER	LEAD	12/30/23 @ 1000
027	164-B	DRINKING WATER	LEAD	12/30/23 @ 1000
028	165-A	DRINKING WATER	LEAD	12/30/23 @ 1000
029	165-B	DRINKING WATER	LEAD	12/30/23 @ 1000
030				

24010254

031	166-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	166-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	167-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	167-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	168-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	168-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	169-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	169-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	170-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	170-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	171-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	171-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	172-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	172-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	173-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	173-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	174-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	174-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	175-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	175-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	176-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	176-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	ICE-1	DRINKING WATER	LEAD	12/30/23 @ 1000
054	ICE-2	DRINKING WATER	LEAD	12/30/23 @ 1000