

January 12, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Wyman Elementary

WorkOrder: 23122012

Dear John Cable:

TEKLAB, INC received 40 samples on 12/27/2023 2:30:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	8
Receiving Check List	11
Chain of Custody	Appended

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23122012-001A	61-A	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 10:44	12/22/2023 12:00
23122012-002A	61-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 10:48	12/22/2023 12:00
23122012-003A	62-A	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 11:54	12/22/2023 12:00
23122012-004A	62-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 10:52	12/22/2023 12:00
23122012-005A	63-A	NELAP		0.0010	0.0027	mg/L	1	01/10/2024 10:56	12/22/2023 12:00
23122012-006A	63-B	NELAP		0.0010	< 0.0010	mg/L	1	01/10/2024 11:25	12/22/2023 12:00
23122012-007A	64-A	NELAP		0.0010	0.0024	mg/L	1	01/10/2024 11:30	12/22/2023 12:00
23122012-008A	64-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 10:48	12/22/2023 12:00
23122012-009A	65-A	NELAP		0.0010	0.0035	mg/L	1	01/11/2024 10:52	12/22/2023 12:00
23122012-010A	65-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 10:56	12/22/2023 12:00
23122012-011A	66-A	NELAP		0.0010	0.0038	mg/L	1	01/11/2024 11:00	12/22/2023 12:00
23122012-012A	66-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:04	12/22/2023 12:00
23122012-013A	67-A	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:08	12/22/2023 12:00
23122012-014A	67-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:16	12/22/2023 12:00
23122012-015A	68-A	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:12	12/22/2023 12:00
23122012-016A	68-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:41	12/22/2023 12:00
23122012-017A	69-A	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:45	12/22/2023 12:00
23122012-018A	69-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:49	12/22/2023 12:00
23122012-019A	70-A	NELAP		0.0010	0.0028	mg/L	1	01/11/2024 11:53	12/22/2023 12:00
23122012-020A	70-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 11:58	12/22/2023 12:00
23122012-021A	71-A	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 12:02	12/22/2023 12:00
23122012-022A	71-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 12:06	12/22/2023 12:00
23122012-023A	72-A	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 12:10	12/22/2023 12:00
23122012-024A	72-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 12:34	12/22/2023 12:00
23122012-025A	73-A	NELAP		0.0010	0.0011	mg/L	1	01/11/2024 12:39	12/22/2023 12:00
23122012-026A	73-B	NELAP		0.0010	< 0.0010	mg/L	1	01/11/2024 12:43	12/22/2023 12:00
23122012-027A	74-A	NELAP		0.0010	0.0030	mg/L	1	01/11/2024 12:47	12/22/2023 12:00
23122012-028A	74-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 0:17	12/22/2023 12:00
23122012-029A	75-A	NELAP		0.0010	0.0035	mg/L	1	01/12/2024 0:21	12/22/2023 12:00
23122012-030A	75-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 0:25	12/22/2023 12:00
23122012-031A	76-A	NELAP		0.0010	0.0027	mg/L	1	01/12/2024 0:30	12/22/2023 12:00
23122012-032A	76-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 0:34	12/22/2023 12:00
23122012-033A	77-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 0:38	12/22/2023 12:00
23122012-034A	77-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 0:46	12/22/2023 12:00
23122012-035A	78-A	NELAP		0.0010	0.0014	mg/L	1	01/12/2024 0:42	12/22/2023 12:00
23122012-036A	78-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:11	12/22/2023 12:00
23122012-037A	79-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:15	12/22/2023 12:00
23122012-038A	79-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:19	12/22/2023 12:00
23122012-039A	80-A	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:23	12/22/2023 12:00
23122012-040A	80-B	NELAP		0.0010	< 0.0010	mg/L	1	01/12/2024 1:27	12/22/2023 12:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216724		SampType: MBLK		Units mg/L						
SampID: MBLK-216724										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/10/2024

Batch 216724		SampType: LCS		Units mg/L						
SampID: LCS-216724										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0535	0.0500	0	106.9	85	115	01/10/2024

Batch 216724		SampType: MS		Units mg/L						
SampID: 23122012-014AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.126	0.1000	0.0007195	125.4	70	130	01/11/2024

Batch 216724		SampType: MSD		Units mg/L						
SampID: 23122012-014AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.127	0.1000	0.0007195	126.6	0.1262	0.87	01/11/2024

Batch 216724		SampType: MS		Units mg/L						
SampID: 23122012-023AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.130	0.1000	0.0003745	129.6	70	130	01/11/2024

Batch 216724		SampType: MSD		Units mg/L						
SampID: 23122012-023AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.128	0.1000	0.0003745	127.3	0.1299	1.74	01/11/2024

Batch 216725		SampType: MBLK		Units mg/L						
SampID: MBLK-216725										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/05/2024

Batch 216725		SampType: LCS		Units mg/L						
SampID: LCS-216725										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0477	0.0500	0	95.4	85	115	01/05/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216725		SampType: MS		Units mg/L						
SampID: 23122010-056AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0925	0.1000	0.0002957	92.2	70	130	01/10/2024

Batch 216725		SampType: MSD		Units mg/L						
SampID: 23122010-056AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0854	0.1000	0.0002957	85.1	0.09254	7.97	01/10/2024

Batch 216725		SampType: MS		Units mg/L						
SampID: 23122012-003AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0985	0.1000	0.0003559	98.1	70	130	01/10/2024

Batch 216725		SampType: MSD		Units mg/L						
SampID: 23122012-003AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0978	0.1000	0.0003559	97.4	0.09845	0.67	01/10/2024

Batch 216728		SampType: MBLK		Units mg/L						
SampID: MBLK-216728										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/11/2024

Batch 216728		SampType: LCS		Units mg/L						
SampID: LCS-216728										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0527	0.0500	0	105.4	85	115	01/11/2024

Batch 216728		SampType: MS		Units mg/L						
SampID: 23122012-034AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.116	0.1000	0.0002596	115.8	70	130	01/12/2024

Batch 216728		SampType: MSD		Units mg/L						
SampID: 23122012-034AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.113	0.1000	0.0002596	113.2	0.1160	2.25	01/12/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216728		SampType: MS		Units mg/L							
SampID: 23122018-002AMS										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010	E	0.118	0.1000	0.001451	116.4	70	130	01/12/2024	

Batch 216728		SampType: MSD		Units mg/L							
SampID: 23122018-002AMSD										RPD Limit: 20	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.119	0.1000	0.001451	117.8	0.1179	1.16	01/12/2024	



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 23122012

Client Project: RPS-Wyman Elementary

Report Date: 12-Jan-24

Carrier: John Cable

Received By: LEH

Completed by: *Mary E. Kemp*
On: *Mary E. Kemp*
28-Dec-23
Mary E Kemp

Reviewed by: *Ellie Hopkins*
On: *Ellie Hopkins*
28-Dec-23
Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- | | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C NA |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

CHAIN OF CUSTODY

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: <u>TRIANGLE ENVIRONMENTAL SCIENCE AND ENGINEERING</u>				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE <u>NA</u> °C			
Address: <u>PO BOX 1026</u>				Preserved In: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u>			
City/State/Zip: <u>ROLLA, MO 65402</u>				LAB NOTES:			
Contact: <u>JOHN CABLE</u>		Phone: <u>573 308 0140</u>		Client Comments:			
Email: <u>TRIANGLE.ENVIRONMENTAL</u>		Fax: <u>@GMAIL.COM</u>					
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
PROJECT NAME/NUMBER		SAMPLE COLLECTOR'S NAME		# and Type of Containers		INDICATE ANALYSIS REQUESTED	
<u>RPS-Wyman Elementary</u>		JOHN W CABLE		UNP HNO3 NaOH H2SO4 HCl MeOH NaHSO4 TSP Other <u>LEAD</u>			
RESULTS REQUESTED		BILLING INSTRUCTIONS					
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> Other		<input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> 3 Day (50% Surcharge) TRIANGLE					
Lab Use Only	Sample ID	Date/Time Sampled	Matrix				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
Relinquished By		Date/Time		Received By		Date/Time	
JOHN W CABLE <u>[Signature]</u>		<u>12/27/23 @ 1430</u>		<u>[Signature]</u>		<u>12/27/23 1430</u>	

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

48-A	DRINKING WATER	LEAD	12/22/23 @ 1200
48-B	DRINKING WATER	LEAD	12/22/23 @ 1200
49-A	DRINKING WATER	LEAD	12/22/23 @ 1200
49-B	DRINKING WATER	LEAD	12/22/23 @ 1200
50-A	DRINKING WATER	LEAD	12/22/23 @ 1200
50-B	DRINKING WATER	LEAD	12/22/23 @ 1200
51-A	DRINKING WATER	LEAD	12/22/23 @ 1200
51-B	DRINKING WATER	LEAD	12/22/23 @ 1200
52-A	DRINKING WATER	LEAD	12/22/23 @ 1200
52-B	DRINKING WATER	LEAD	12/22/23 @ 1200
53-A	DRINKING WATER	LEAD	12/22/23 @ 1200
53-B	DRINKING WATER	LEAD	12/22/23 @ 1200
54-A	DRINKING WATER	LEAD	12/22/23 @ 1200
54-B	DRINKING WATER	LEAD	12/22/23 @ 1200
55-A	DRINKING WATER	LEAD	12/22/23 @ 1200
56-A	DRINKING WATER	LEAD	12/22/23 @ 1200
56-B	DRINKING WATER	LEAD	12/22/23 @ 1200
57-A	DRINKING WATER	LEAD	12/22/23 @ 1200
57-B	DRINKING WATER	LEAD	12/22/23 @ 1200
58-A	DRINKING WATER	LEAD	12/22/23 @ 1200
58-B	DRINKING WATER	LEAD	12/22/23 @ 1200
59-A	DRINKING WATER	LEAD	12/22/23 @ 1200
59-B	DRINKING WATER	LEAD	12/22/23 @ 1200
60-A	DRINKING WATER	LEAD	12/22/23 @ 1200
60-B	DRINKING WATER	LEAD	12/22/23 @ 1200
61-A	DRINKING WATER	LEAD	12/22/23 @ 1200
61-B	DRINKING WATER	LEAD	12/22/23 @ 1200
62-A	DRINKING WATER	LEAD	12/22/23 @ 1200
62-B	DRINKING WATER	LEAD	12/22/23 @ 1200
63-A	DRINKING WATER	LEAD	12/22/23 @ 1200
63-B	DRINKING WATER	LEAD	12/22/23 @ 1200
64-A	DRINKING WATER	LEAD	12/22/23 @ 1200
64-B	DRINKING WATER	LEAD	12/22/23 @ 1200
65-A	DRINKING WATER	LEAD	12/22/23 @ 1200
65-B	DRINKING WATER	LEAD	12/22/23 @ 1200
66-A	DRINKING WATER	LEAD	12/22/23 @ 1200
66-B	DRINKING WATER	LEAD	12/22/23 @ 1200
67-A	DRINKING WATER	LEAD	12/22/23 @ 1200
67-B	DRINKING WATER	LEAD	12/22/23 @ 1200
68-A	DRINKING WATER	LEAD	12/22/23 @ 1200
68-B	DRINKING WATER	LEAD	12/22/23 @ 1200
69-A	DRINKING WATER	LEAD	12/22/23 @ 1200
69-B	DRINKING WATER	LEAD	12/22/23 @ 1200
70-A	DRINKING WATER	LEAD	12/22/23 @ 1200
70-B	DRINKING WATER	LEAD	12/22/23 @ 1200
71-A	DRINKING WATER	LEAD	12/22/23 @ 1200
71-B	DRINKING WATER	LEAD	12/22/23 @ 1200

23122012-001
 002
 003
 004
 005
 006
 007
 008
 009
 010
 011
 012
 013
 014
 015
 016
 017
 018
 019
 020
 021
 022

72-A	DRINKING WATER	LEAD	12/22/23 @ 1200	23122012-023
72-B	DRINKING WATER	LEAD	12/22/23 @ 1200	024
73-A	DRINKING WATER	LEAD	12/22/23 @ 1200	025
73-B	DRINKING WATER	LEAD	12/22/23 @ 1200	026
74-A	DRINKING WATER	LEAD	12/22/23 @ 1200	027
74-B	DRINKING WATER	LEAD	12/22/23 @ 1200	028
75-A	DRINKING WATER	LEAD	12/22/23 @ 1200	029
75-B	DRINKING WATER	LEAD	12/22/23 @ 1200	030
76-A	DRINKING WATER	LEAD	12/22/23 @ 1200	031
76-B	DRINKING WATER	LEAD	12/22/23 @ 1200	032
77-A	DRINKING WATER	LEAD	12/22/23 @ 1200	033
77-B	DRINKING WATER	LEAD	12/22/23 @ 1200	034
78-A	DRINKING WATER	LEAD	12/22/23 @ 1200	035
78-B	DRINKING WATER	LEAD	12/22/23 @ 1200	036
79-A	DRINKING WATER	LEAD	12/22/23 @ 1200	037
79-B	DRINKING WATER	LEAD	12/22/23 @ 1200	038
80-A	DRINKING WATER	LEAD	12/22/23 @ 1200	039
80-B	DRINKING WATER	LEAD	12/22/23 @ 1200	040
81-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
81-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
82-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
82-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
83-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
83-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
84-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
84-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
85-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
85-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
86-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
86-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
87-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
87-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
88-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
88-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
89-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
89-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
90-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
90-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
91-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
91-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
92-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
92-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
93-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
93-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
94-A	DRINKING WATER	LEAD	12/22/23 @ 1200	
94-B	DRINKING WATER	LEAD	12/22/23 @ 1200	
95-A	DRINKING WATER	LEAD	12/22/23 @ 1200	



95-B	DRINKING WATER	LEAD	12/22/23 @ 1200
96-A	DRINKING WATER	LEAD	12/22/23 @ 1200
96-B	DRINKING WATER	LEAD	12/22/23 @ 1200
97-A	DRINKING WATER	LEAD	12/22/23 @ 1200
97-B	DRINKING WATER	LEAD	12/22/23 @ 1200
98-A	DRINKING WATER	LEAD	12/22/23 @ 1200
98-B	DRINKING WATER	LEAD	12/22/23 @ 1200
99-A	DRINKING WATER	LEAD	12/22/23 @ 1200
99-B	DRINKING WATER	LEAD	12/22/23 @ 1200
100-A	DRINKING WATER	LEAD	12/22/23 @ 1200
100-B	DRINKING WATER	LEAD	12/22/23 @ 1200
101-A	DRINKING WATER	LEAD	12/22/23 @ 1200
101-B	DRINKING WATER	LEAD	12/22/23 @ 1200
102-A	DRINKING WATER	LEAD	12/22/23 @ 1200
102-B	DRINKING WATER	LEAD	12/22/23 @ 1200
103-A	DRINKING WATER	LEAD	12/22/23 @ 1200
103-B	DRINKING WATER	LEAD	12/22/23 @ 1200
104-A	DRINKING WATER	LEAD	12/22/23 @ 1200
104-B	DRINKING WATER	LEAD	12/22/23 @ 1200
105-A	DRINKING WATER	LEAD	12/22/23 @ 1200
105-B	DRINKING WATER	LEAD	12/22/23 @ 1200
106-A	DRINKING WATER	LEAD	12/22/23 @ 1200
106-B	DRINKING WATER	LEAD	12/22/23 @ 1200
107-A	DRINKING WATER	LEAD	12/22/23 @ 1200
107-B	DRINKING WATER	LEAD	12/22/23 @ 1200
108-A	DRINKING WATER	LEAD	12/22/23 @ 1200
108-B	DRINKING WATER	LEAD	12/22/23 @ 1200
109-A	DRINKING WATER	LEAD	12/22/23 @ 1200
109-B	DRINKING WATER	LEAD	12/22/23 @ 1200
110-A	DRINKING WATER	LEAD	12/22/23 @ 1200
110-B	DRINKING WATER	LEAD	12/22/23 @ 1200
111-A	DRINKING WATER	LEAD	12/22/23 @ 1200
111-B	DRINKING WATER	LEAD	12/22/23 @ 1200
112-A	DRINKING WATER	LEAD	12/22/23 @ 1200
112-B	DRINKING WATER	LEAD	12/22/23 @ 1200
113-A	DRINKING WATER	LEAD	12/22/23 @ 1200
113-B	DRINKING WATER	LEAD	12/22/23 @ 1200
114-A	DRINKING WATER	LEAD	12/22/23 @ 1200
114-B	DRINKING WATER	LEAD	12/22/23 @ 1200
115-A	DRINKING WATER	LEAD	12/22/23 @ 1200
115-B	DRINKING WATER	LEAD	12/22/23 @ 1200
116-A	DRINKING WATER	LEAD	12/22/23 @ 1200
116-B	DRINKING WATER	LEAD	12/22/23 @ 1200
117-A	DRINKING WATER	LEAD	12/22/23 @ 1200
117-B	DRINKING WATER	LEAD	12/22/23 @ 1200
118-A	DRINKING WATER	LEAD	12/22/23 @ 1200
118-B	DRINKING WATER	LEAD	12/22/23 @ 1200

119-A	DRINKING WATER	LEAD	12/22/23 @ 1200
119-B	DRINKING WATER	LEAD	12/22/23 @ 1200
120-A	DRINKING WATER	LEAD	12/22/23 @ 1200
120-B	DRINKING WATER	LEAD	12/22/23 @ 1200
121-A	DRINKING WATER	LEAD	12/22/23 @ 1200
121-B	DRINKING WATER	LEAD	12/22/23 @ 1200
122-A	DRINKING WATER	LEAD	12/22/23 @ 1200
122-B	DRINKING WATER	LEAD	12/22/23 @ 1200
123-A	DRINKING WATER	LEAD	12/22/23 @ 1200
123-B	DRINKING WATER	LEAD	12/22/23 @ 1200
124-A	DRINKING WATER	LEAD	12/22/23 @ 1200
124-B	DRINKING WATER	LEAD	12/22/23 @ 1200
125-A	DRINKING WATER	LEAD	12/22/23 @ 1200
125-B	DRINKING WATER	LEAD	12/22/23 @ 1200